



- Tank joint sealed with CS 101 butyl rubber sealant
- Tank is constructed of reinforced concrete with a minimum compressive strength of 5000 psi
- Tank is designed to support 3' of burial depth plus AASHTO HS20-44 loading
- Traffic rated CI frame and covers are placed on traffic rated concrete grade rings
- Rubber pipe seals with stainless steel clamps are designed to meet or exceed ASTM C-1644